

On 6/30/17 the Violation Was IFC 605.1 - Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the responsible code official.

These are the notes that were on file.

I was called by E8 that a citizen had come into station 8 to complain about a dangerous situation at the new YMCA. They stated there was electrical cords and equipment lying in water and in between the pools and they felt this presented a danger to the kids and adults in the pool area.

I responded to the site at which time I was greeted at the door by personnel who told me they knew about the situation and had felt it was dangerous. I went to the pool area to find extension cords lying in water between the pools along with a monitor and music equipment in between the two pool areas that had water splashing and overlapping the cords. I felt this was a dangerous situation and had them unplug the cords and equipment and remove them from between the pools. I discussed this with the manager onsite and let him know this is a dangerous practice.

I contacted the Allen County Building Department John Caywood and Curtis Auld. I could not reach them initially. They did both call me back and I explained the situation, which had already been resolved.